

VIBRATION ACCEPTANCE TEST REPORT

SAMPLE REPORT

Data Collected: 5/31/13



SAMPLE REPORT

TABLE OF CONTENTS

CLICK ON THE AREA OF INTEREST BELOW:		PAGE
SCOPE OF PROJECT AND OVERVIEW	_____	3
PUMP 1 SUMMARY	_____	5
VELOCITY VALUES SUMMARY GRAPH	_____	6
DISPLACEMENT VALUES SUMMARY GRAPH	_____	7
PUMP 2 SUMMARY	_____	8
VELOCITY VALUES SUMMARY GRAPH	_____	9
DISPLACEMENT VALUES SUMMARY GRAPH	_____	10
PUMP 3 SUMMARY	_____	11
VELOCITY VALUES SUMMARY GRAPH	_____	12
DISPLACEMENT VALUES SUMMARY GRAPH	_____	13
 <u>ATTACHMENTS</u>		
KIRK CORMANY ANSI LEVEL III VIBRATION ANALYST CERTIFICATION	_____	14
ANALYZER CALIBRATION CERTIFICATE.	_____	16





To: Sample Client

June 11, 2013

RE: Job Number ABC

To Whom it May Concern,

As requested, please find the results of the shop vibration data collection and bearing temperature readings taken on the pumps at your facility on May 31, 2013.

Scope:

Vibration was collected using a portable CSI 2130 vibration analyzer and 100 mV/g accelerometer connected to a 70lb pull rated magnetic base. Data was collected at 1600 lines resolution exceeding 40 orders of shaft rpm. In review of the pump type and applicable standards, the test pass criteria is based on meeting Hydraulic Institute Applied standard - 9.9.4.2.5.1c Allowable pump vibration, Solids Handling pump types located in ANSI/HI PUB 9.6.4 – 2009.

This particular standard does not allow for separate levels of criteria between shop and field testing. This criterion also only refers to specific measurement point locations at the base of the motor support flange. For the balance of the data collected the limitations of .40 ips/rms and 6.0 mils/pk was applied.

Data was reviewed in Acceleration and Velocity on a frequency basis for the presence of non-synchronous energy that would indicate the presence of defects within the motor bearing raceways, rollers, and cage assembly and found to be acceptable. A table of common bearing defect frequencies is provided below and is referred to in orders of 1x shaft rpm:

BRG ID	BEARING TYPE	#B/R	FTF	BSF	BPFO	BPFI
Top Guide Bearing	3318	14	.415	2.413	5.806	8.194
Bottom Guide Bearing	6310	8	.381	1.980	3.047	4.953

Bearing temperature was recorded at start, mid 15 min intervals, and then at end run. The bearing temperature data refers to end run values and was stable throughout test. Flow, amperage, voltage, and discharge pressure values were also recorded. Pumps were run with clear liquid at 60 Hz line frequency. Bump tests were performed at each location in the X, Y, and Axial planes on the motor top and bottom bearings, pump volute, suction and discharge locations.



Tabular information overview:

The bump test table provides the frequency response of each axis with least desirable response identified and is tabulated in three formats that refer to orders of shaft rpm, actual frequency in CPM, and percent of allowable band tolerances. Where there is no entry, there was no frequency response. Generally speaking, these pumps had a lower maximum response of .5 x shaft speed and upper response of 1.7 x shaft speed, which are both well away from the 15% band of shaft speed that would be considered unacceptable. There were no higher frequencies noted in the bump test and there was no discernible vane pass vibration energy noted in the spectral data, so for this test consideration of resonant responses is limited to shaft rpm.

For the vibration results the measurement points are listed with results in velocity and displacement and indication of pass or fail along with the applied limits.

Additional information:

Attached at the end of this report are analyst certifications and analyzer calibration certificate.

I trust this report content meets your requirements.

Please free to touch base at anytime if you need additional information.


Best Regards,

Kirk Cormany
Level III Vibration Analyst
Condition Monitoring Services, Inc
kcormany@conditionmonitoringservices.com
Cell 805-478-0797
Office 888-359-3277



VIBRATION ACCEPTANCE TEST REPORT

COMPANY:	Sample Client	VSD DRIVE HERTZ:	60
PUMP SERIAL:	A1	AMPERAGE:	48
PUMP DISCHARGE PSI:	41	VOLTAGE:	448
FLOW GPM:	722	HEADER SIZE:	6"
		PUMP RPM:	1780



Vertical solids, close coupled

Recorded Motor Bearing Temperatures °F

Top 93 °F Bottom 98 °F

STANDARDS

Standard - .32 IPS / RMS (no allowance for shop testing)
Applied standard - 9.9.4.2.5.1c Allowable pump vibration, Solids Handling pump types.
Reference: Hydraulic Institute Standard 9.6.4 - 2009

Other applicable standards - .40 IPS or 6 Mills Pk at any point

Reference: Customer Documentation

Bump Testing: Frequency responses cannot be within 15% of known rotational forces. (1x shaft speed and vane pass at 9x)

Bump Test Frequency Responses


	Orders		CPM		Percent Shaft 1x	
X - Crossline to flow	0.65	1.83	1179.75	3321.45	65%	183%
Y - Inline with flow	0.51	1.57	925.65	2849.55	51%	157%
A - Axial	0.53	N/A	961.95	N/A	53%	N/A
Response limits based on 15% band	0.85	1.15	1542.75	2087.25	85%	115%

Vibration Results

			Vel / RMS	Std	Pass/Fail	Mils PK	Std	Pass/Fail
MTY	-	MOTOR TOP BEARING INLINE (Y)	0.13	0.4	PASS	3.2	6	PASS
MTX	-	MOTOR TOP BEARING CROSSLINE (X)	0.18	0.4	PASS	4.3	6	PASS
MBY	-	MOTOR BTTM INLINE TO FLOW (Y)	0.06	0.4	PASS	0.5	6	PASS
MBX	-	MOTOR BTTM CROSSLINE TO FLOW (X)	0.12	0.4	PASS	1.5	6	PASS
MBA	-	MOTOR BTTM AXIAL CROSSLINE (A)	0.11	0.4	PASS	3.4	6	PASS
P1Y	-	PUMP INLINE TO FLOW (Y) 9.6.4	0.06	0.32	PASS	0.7	6	PASS
P1X	-	PUMP CROSSLINE TO FLOW (X) 9.6.4	0.12	0.32	PASS	2.0	6	PASS
P1A	-	PUMP AXIAL (A) 9.6.4	0.09	0.32	PASS	1.8	6	PASS
P2X	-	PUMP BTTM CROSSLINE TO FLOW (X)	0.18	0.4	PASS	3.4	6	PASS
P2Y	-	PUMP BTTM INLINE TO FLOW (Y)	0.11	0.4	PASS	1.3	6	PASS
P3X	-	PUMP SUCTION PIPE (X)	0.25	0.4	PASS	3.5	6	PASS
P3Y	-	PUMP SUCTION PIPE (Y)	0.18	0.4	PASS	1.5	6	PASS
P3Z	-	PUMP SUCTION PIPE (Z)	0.13	0.4	PASS	1.6	6	PASS
P4X	-	PUMP DISCHARGE PIPE (X)	0.30	0.4	PASS	4.4	6	PASS
P4Y	-	PUMP DISCHARGE PIPE (Y)	0.22	0.4	PASS	1.8	6	PASS
P4Z	-	PUMP DISCHARGE PIPE (Z)	0.17	0.4	PASS	1.9	6	PASS


PUMP 1

VELOCITY VALUES VS. LIMIT



PUMP 1


DISPLACEMENT VALUES VS. LIMIT





VIBRATION ACCEPTANCE TEST REPORT

COMPANY:	SAMPLE CLIENT	VSD DRIVE HERTZ:	60
PUMP SERIAL:	B2	AMPERAGE:	47
PUMP DISCHARGE PSI:	37	VOLTAGE:	452
FLOW GPM:	715	HEADER SIZE:	6"
		PUMP RPM:	1780



Vertical solids,
close coupled

Recorded Motor Bearing Temperatures °F

Top 94 °F Bottom 100 °F

STANDARDS

Standard - .32 IPS / RMS (no allowance for shop testing)
Applied standard - 9.9.4.2.5.1c Allowable pump vibration, Solids Handling pump types.
Reference: Hydraulic Institute Standard 9.6.4 - 2009

Other applicable standards - .40 IPS or 6 Mills Pk at any point

Reference: Customer Documentation

Bump Testing: Frequency responses cannot be within 15% of known rotational forces. (1x shaft speed and vane pass at 9x)

Bump Test Frequency Responses


	Orders		CPM		Percent Shaft 1x	
X - Crossline to flow	0.44	1.76	798.6	3194.4	44%	176%
Y - Inline with flow	0.44	1.48	798.6	2686.2	44%	148%
A - Axial	0.49	N/A	889.35	N/A	49%	N/A
Response limits based on 15% band	0.85	1.15	1542.75	2087.25	85%	115%

Vibration Results

			Vel / RMS	Std	Pass/Fail	Mils PK	Std	Pass/Fail
MTY	-	MOTOR TOP BEARING INLINE (Y)	0.10	0.4	PASS	3.1	6	PASS
MTX	-	MOTOR TOP BEARING CROSSLINE (X)	0.19	0.4	PASS	2.2	6	PASS
MBY	-	MOTOR BTTM INLINE TO FLOW (Y)	0.05	0.4	PASS	0.8	6	PASS
MBX	-	MOTOR BTTM CROSSLINE TO FLOW (X)	0.12	0.4	PASS	0.8	6	PASS
MBA	-	MOTOR BTTM AXIAL CROSSLINE (A)	0.08	0.4	PASS	1.5	6	PASS
P1Y	-	PUMP INLINE TO FLOW (Y) 9.6.4	0.12	0.32	PASS	0.7	6	PASS
P1X	-	PUMP CROSSLINE TO FLOW (X) 9.6.4	0.14	0.32	PASS	1.7	6	PASS
P1A	-	PUMP AXIAL (A) 9.6.4	0.11	0.32	PASS	1.9	6	PASS
P2X	-	PUMP BTTM CROSSLINE TO FLOW (X)	0.21	0.4	PASS	1.7	6	PASS
P2Y	-	PUMP BTTM INLINE TO FLOW (Y)	0.14	0.4	PASS	0.6	6	PASS
P3X	-	PUMP SUCTION PIPE (X)	0.27	0.4	PASS	1.6	6	PASS
P3Y	-	PUMP SUCTION PIPE (Y)	0.23	0.4	PASS	1.9	6	PASS
P3Z	-	PUMP SUCTION PIPE (Z)	0.15	0.4	PASS	0.7	6	PASS
P4X	-	PUMP DISCHARGE PIPE (X)	0.26	0.4	PASS	3.0	6	PASS
P4Y	-	PUMP DISCHARGE PIPE (Y)	0.26	0.4	PASS	2.4	6	PASS
P4Z	-	PUMP DISCHARGE PIPE (Z)	0.18	0.4	PASS	3.0	6	PASS


PUMP 2

VELOCITY VALUES VS. LIMITS



PUMP 2


DISPLACEMENT VALUES VS. LIMITS





VIBRATION ACCEPTANCE TEST REPORT

COMPANY:	SAMPLE CLIENT	VSD DRIVE HERTZ:	60
PUMP SERIAL:	C3	AMPERAGE:	49
PUMP DISCHARGE PSI:	40.7	VOLTAGE:	445
FLOW GPM:	726	HEADER SIZE:	6"
		PUMP RPM:	1780



Vertical solids, close coupled

Recorded Motor Bearing Temperatures °F

Top 106 °F Bottom 100 °F

STANDARDS

Standard - .32 IPS / RMS (no allowance for shop testing)
Applied standard - 9.9.4.2.5.1c Allowable pump vibration, Solids Handling pump types.
Reference: Hydraulic Institute Standard 9.6.4 - 2009

Other applicable standards - .40 IPS or 6 Mills Pk at any point

Reference: Customer Documentation

Bump Testing: Frequency responses cannot be within 15% of known rotational forces. (1x shaft speed and vane pass at 9x)

Bump Test Frequency Responses


	Orders		CPM		Percent Shaft 1x	
X - Crossline to flow	0.16	1.85	290.4	3357.75	16%	185%
Y - Inline with flow	0.44	1.84	798.6	3339.6	44%	184%
A - Axial	0.50	1.78	907.5	3230.7	50%	178%
Response limits based on 15% band	0.85	1.15	1542.75	2087.25	85%	115%

Vibration Results

			Vel / RMS	Std	Pass/Fail	Mils PK	Std	Pass/Fail
MTY	-	MOTOR TOP BEARING INLINE (Y)	0.09	0.4	PASS	1.6	6	PASS
MTX	-	MOTOR TOP BEARING CROSSLINE (X)	0.17	0.4	PASS	3.0	6	PASS
MBY	-	MOTOR BTTM INLINE TO FLOW (Y)	0.05	0.4	PASS	0.5	6	PASS
MBX	-	MOTOR BTTM CROSSLINE TO FLOW (X)	0.12	0.4	PASS	1.8	6	PASS
MBA	-	MOTOR BTTM AXIAL CROSSLINE (A)	0.07	0.4	PASS	1.2	6	PASS
P1Y	-	PUMP INLINE TO FLOW (Y) 9.6.4	0.08	0.32	PASS	0.8	6	PASS
P1X	-	PUMP CROSSLINE TO FLOW (X) 9.6.4	0.19	0.32	PASS	2.5	6	PASS
P1A	-	PUMP AXIAL (A) 9.6.4	0.10	0.32	PASS	2.5	6	PASS
P2X	-	PUMP BTTM CROSSLINE TO FLOW (X)	0.24	0.4	PASS	3.8	6	PASS
P2Y	-	PUMP BTTM INLINE TO FLOW (Y)	0.11	0.4	PASS	1.3	6	PASS
P3X	-	PUMP SUCTION PIPE (X)	0.26	0.4	PASS	4.4	6	PASS
P3Y	-	PUMP SUCTION PIPE (Y)	0.20	0.4	PASS	3.0	6	PASS
P3Z	-	PUMP SUCTION PIPE (Z)	0.12	0.4	PASS	1.5	6	PASS
P4X	-	PUMP DISCHARGE PIPE (X)	0.23	0.4	PASS	4.5	6	PASS
P4Y	-	PUMP DISCHARGE PIPE (Y)	0.21	0.4	PASS	3.0	6	PASS
P4Z	-	PUMP DISCHARGE PIPE (Z)	0.15	0.4	PASS	1.5	6	PASS

PUMP 3

VELOCITY VALUES VS. LIMIT



PUMP 3

DISPLACEMENT VALUES VS. LIMIT

